



Lexington, NC Supplemental Dehumidification Case Study

Last Check-in: 9/2/2014 11:48 AM
Expected Next Check-in: 9/2/2014 11:58 AM

Belongs to Network: IDS Second
GatewayID: 9419



UNIT 210 (UNOCCUPIED) – 1.5T Split System Cooling ONLY

Average Temperature Range 74-78 degrees, Average Relative Humidity 67-71%

Last Check-in: 9/2/2014 11:50 AM
Expected Next Check-in: 9/2/2014 12:10 PM

Belongs to Network: IDS Second
GatewayID: 9419



UNIT 416 (OCCUPIED) – 1.5T Split System Cooling with IW-25 In-Wall Dehumidifier

Average Temperature Range 76-77 degrees, Average Relative Humidity 45-47%